



Sacramento Metropolitan Fire District

Fire Company Inspection Program

10545 Armstrong Ave., Suite 310 • Mather, CA 95655 • Phone (916) 859-4330 • Fax (916) 859-3717

Todd Harms
Fire Chief

ADDRESSING

All buildings are required to have the street address posted. Addresses should be visible from the street, in **minimum of 6 inch** numbers that contrast with their background. In addition, the addresses shall be internally or externally illuminated.

Another consideration is the location of the numbers. Numbering shall not be obstructed by trees, exterior walls or any other object which would hinder the view of the numbers. If an obstruction is present, it shall either be removed or the numbering shall be relocated to a visible location.

In buildings with multiple suites or businesses, the individual suites or businesses shall also be clearly identified, by placing the suite number over or on the main entry/exit door. The address shall be clearly visible and be of a contrasting color. Any other doors providing access to the suite or business shall be marked in the same manner.

A directory board is required at the entrance to a large commercial complex when the buildings are not clearly visible and identifiable from the street. Apartment building numbers shall be identified in the same manner as addresses. Apartment units within the buildings shall be clearly identified on the building placard. Individual apartments shall be identified by placing the unit number on or adjacent to the door.

